

**STATEMENT OF IMPLEMENTATION REPORT ON ASSURANCE**  
**No.18 Dated: 27-7-2007**

**GIST OF ASSURANCE**

The Hon'ble Minister for Rural Water Supply & Sanitation has given Assurance in the House on 27-07-2007 that pressure on supply of drinking water is increased in Patancheru and R.C.Puram mandals in Medak district due to urbanization, industrialization and increase in population. But as per the norms of RWS department, 40 LPCD's water has to be supplied to 44 villages in Patancheru area and 14 villages in Ramachandrapuram area. But the people of these areas are requesting for 50 to 70 LPCD's of drinking water. The Hon'ble Minister, Rural Water Supply & Sanitation has assured to solve the problems of the above said villages.

**IMPLEMENTATION REPORT**

There are 14 rural habitations out of 15 habitations in R.C.puram(M) and 44 rural habitations out of 45 habitations in Patancheru mandal .

Drinking water is being supplied to the above 58 rural habitations by a net work of 4 CPWS Schemes only for drinking purpose. In addition, the existing PWS Schemes & bore wells are serving the other needs of the villagers.

The details of quantity of Manjeera drinking water and water from other schemes being supplied to each habitation is appended(Annexure-I)

Out of the 40 LPCPD that has to be supplied as per RWS norms 8 LPCPD is for drinking and cooking purpose. Against the requirement of 8 LPCPD much higher quantum of drinking water from Manjeera for all the 58 rural habitations of the said two Mandals is being supplied. Since the water is supplied from Manjeera on cost basis it is not possible to

**increase the per capita level of supply for the rural habitations. The overall norms of 40 LPCPD is already satisfied for all the rural habitations.**

**Therefore the Assurance may please be treated as implemented.**

**P. VISWA ROOP  
MINISTER FOR RURAL WATER SUPPLY AND  
SANITATION**